

PUBLIC HEALTH ENGINEERING DEPARTMENT
Regional Water Testing Laboratory

District Name : Muzaffarpur

Month -January 2026

Sl. No.	Block	Panchayat	Village	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	NO ₃	F	As	MPN	Remarks
1	Sariya	Godinathpur Dokra	Godinathpur Dokra	-	Arbhika Bhawani Public School	7.2	1	460	426	190	31.68	18.46	24	120	0.31	20	5	0.2	BDL	NIL	
Acceptable Limit (IS 10500-2012)						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	45 mg/l	1.0 ppm	0.01 ppm	0.01 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)						NIR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	1.5 ppm	NR	0.1 mg/l	


 Chemist 5101126
CHEMIST
 RWTL Muzaffarpur
 R.W.T.L. MUZAFFARPUR